

RGU FIRE STATISTICS 1st AUGUST 2015 TO 31st JULY 2016

COMPILED BY:	Alan Fleming, Fire Safety Adviser
PHONE:	01224 262082
EMAIL:	a.fleming3@rgu.ac.uk

HALLS OF RESIDENCE FIRES	
Total number of major fires*:	0
Total number of minor fires*:	1
Total number of near miss fire incidents*:	0
Total number cooking fires:	2
Total number of external fires:	0
Number of internal that do not result in fire alarm activations:	0
Summarise briefly the nature of the fire(s)/ incidents below:	
Minor fire - tea towel left on hob	

**Refer to definition*

FALSE ALARMS	
Number of malicious alarms:	2
Number of other false activations:	85
Total number of fire alarm activations	90

INJURIES FROM FIRE	
Number of injuries as a result of fire:	0
Summarise briefly the nature of the injuries below:	

Total number of Fire & Rescue Services attendance:	1
Number of automatic detectors:	859

ALL OTHER BUILDING FIRES	
Total number of major fires*:	0
Total number of minor fires*:	0
Total number of near miss fire incidents*:	2
Total number of cooking fires:	0
Total number of external fires:	0
Number of internal that do not result in fire alarm activations:	0
Summarise briefly the nature of the fire(s)/ incidents below:	
Near miss – RGU Sport, faulty fridge transformer overheated, melted and produced fumes. Near miss – SIWB, circuit board blew due to faulty wiring.	

**Refer to definition*

FALSE ALARMS	
Number of malicious alarms:	0
Number of other false activations:	24
Total number of fire alarm activations	26

INJURIES FROM FIRE	
Number of injuries as a result of fire:	0
Summarise briefly the nature of the injuries below:	

Total number of Fire & Rescue Services attendance:	15
Number of automatic detectors:	2720