

**RGU FIRE STATISTICS 1<sup>st</sup> AUGUST 2013 TO 31<sup>st</sup> JULY 2014**

<b>COMPILED BY:</b>	<b>Alan Fleming, Fire Safety Adviser</b>
<b>PHONE:</b>	<b>01224 262082</b>
<b>EMAIL:</b>	<b>a.fleming3@rgu.ac.uk</b>

<b>HALLS OF RESIDENCE FIRES</b>	
Total number of major fires*:	<b>0</b>
Total number of minor fires*:	<b>4</b>
Total number of near miss fire incidents*:	<b>0</b>
Total number cooking fires:	<b>4</b>
Total number of external fires:	<b>0</b>
Number of internal that do not result in fire alarm activations:	<b>0</b>
Summarise briefly the nature of the fire(s)/ incidents below:	
4 small cooking oil fire which were quickly extinguished.	

*\*Refer to definition*

<b>FALSE ALARMS</b>	
Number of malicious alarms:	<b>5</b>
Number of other false activations:	<b>113</b>
Total number of fire alarm activations	<b>122</b>

<b>INJURIES FROM FIRE</b>	
Number of injuries as a result of fire:	<b>0</b>
Summarise briefly the nature of the injuries below:	

Total number of Fire & Rescue Services attendance:	<b>2</b>
Number of automatic detectors:	<b>872</b>

<b>ALL OTHER BUILDING FIRES</b>	
Total number of major fires*:	<b>0</b>
Total number of minor fires*:	<b>0</b>
Total number of near miss fire incidents*:	<b>1</b>
Total number of cooking fires:	<b>0</b>
Total number of external fires:	<b>0</b>
Number of internal that do not result in fire alarm activations:	<b>0</b>
Summarise briefly the nature of the fire(s)/ incidents below:	
Near miss incident involved faulty electrical switchgear which started smoking.	

*\*Refer to definition*

<b>FALSE ALARMS</b>	
Number of malicious alarms:	<b>0</b>
Number of other false activations:	<b>13</b>
Total number of fire alarm activations	<b>14</b>

<b>INJURIES FROM FIRE</b>	
Number of injuries as a result of fire:	<b>0</b>
Summarise briefly the nature of the injuries below:	

Total number of Fire & Rescue Services attendance:	<b>8</b>
Number of automatic detectors:	<b>2641</b>