

RGU FIRE STATISTICS 1st AUGUST 2012 TO 31st JULY 2013

COMPILED BY:	Alan Fleming, Fire Safety Adviser
PHONE:	01224 262082
EMAIL:	a.fleming3@rgu.ac.uk

HALLS OF RESIDENCE FIRES	
Total number of major fires*:	0
Total number of minor fires*:	1
Total number of near miss fire incidents*:	1
Total number cooking fires:	1
Total number of external fires:	0
Number of internal that do not result in fire alarm activations:	0
Summarise briefly the nature of the fire(s)/ incidents below:	
Chip pan fire resulting in injury to hand. Near miss incident involve a faulty new microwave which started smoking when switched on.	

**Refer to definition*

FALSE ALARMS	
Number of malicious alarms:	4
Number of other false activations:	103
Total number of fire alarm activations	107

INJURIES FROM FIRE	
Number of injuries as a result of fire:	1
Summarise briefly the nature of the injuries below:	
Chip pan fire resulting in injury to hand.	

Total number of Fire & Rescue Services attendance:	16
Number of automatic detectors:	872

ALL OTHER BUILDING FIRES	
Total number of major fires*:	0
Total number of minor fires*:	1
Total number of near miss fire incidents*:	0
Total number of cooking fires:	0
Total number of external fires:	0
Number of internal that do not result in fire alarm activations:	0
Summarise briefly the nature of the fire(s)/ incidents below:	
Accidental ignition of cotton wool in laboratory – extinguished by pipette.	

**Refer to definition*

FALSE ALARMS	
Number of malicious alarms:	0
Number of other false activations:	12
Total number of fire alarm activations	1

INJURIES FROM FIRE	
Number of injuries as a result of fire:	0
Summarise briefly the nature of the injuries below:	

Total number of Fire & Rescue Services attendance:	7
Number of automatic detectors:	2641