

RGU FIRE STATISTICS 1st AUGUST 2019 TO 31st JULY 2020

| | |
|---------------------|--|
| COMPILED BY: | Alan Fleming, Fire Safety Adviser |
| PHONE: | 01224 262082 |
| EMAIL: | a.fleming3@rgu.ac.uk |

| HALLS OF RESIDENCE FIRES | |
|--|----------|
| Total number of major fires: | 0 |
| Total number of minor fires: | 0 |
| Total number of near miss fire incidents: | 0 |
| Total number cooking fires: | 0 |
| Total number of external fires: | 0 |
| Number of internal that do not result in fire alarm activations: | 0 |
| Summarise briefly the nature of the fire(s)/ incidents below: | |
| | |

| FALSE ALARMS | |
|--|-----------|
| Number of malicious alarms: | 1 |
| Number of other false activations: | 52 |
| Total number of fire alarm activations | 53 |

| INJURIES FROM FIRE | |
|---|----------|
| Number of injuries as a result of fire: | 0 |
| Summarise briefly the nature of the injuries below: | |
| | |

| | |
|--|------------|
| Total number of Fire & Rescue Services attendance: | 3 |
| Number of automatic detectors: | 910 |

| ALL OTHER BUILDING FIRES | |
|---|----------|
| Total number of major fires: | 0 |
| Total number of minor fires: | 0 |
| Total number of near miss fire incidents: | 1 |
| Total number of cooking fires: | 0 |
| Total number of external fires: | 0 |
| Number of internal that do not result in fire alarm activations: | 1 |
| Summarise briefly the nature of the fire(s)/ incidents below: | |
| Near Miss – During class in N533 vape device started smoking in a coat pocket. Device removed from building. Alarm did not actuate. | |

| FALSE ALARMS | |
|--|----------|
| Number of malicious alarms: | 0 |
| Number of other false activations: | 9 |
| Total number of fire alarm activations | 9 |

| INJURIES FROM FIRE | |
|---|----------|
| Number of injuries as a result of fire: | 0 |
| Summarise briefly the nature of the injuries below: | |
| | |

| | |
|--|-------------|
| Total number of Fire & Rescue Services attendance: | 3 |
| Number of automatic detectors: | 3287 |