

RGU FIRE STATISTICS 1st AUGUST 2018 TO 31st JULY 2019

COMPILED BY:	Alan Fleming, Fire Safety Adviser
PHONE:	01224 262082
EMAIL:	a.fleming3@rgu.ac.uk

HALLS OF RESIDENCE FIRES	
Total number of major fires:	0
Total number of minor fires:	0
Total number of near miss fire incidents:	0
Total number cooking fires:	0
Total number of external fires:	1
Number of internal that do not result in fire alarm activations:	0
Summarise briefly the nature of the fire(s)/ incidents below:	
External fire – Person at Woolmanhill in smoking shelter found with clothing on fire. Person taken to hospital and received treatment for burns.	

FALSE ALARMS	
Number of malicious alarms:	2
Number of other false activations:	64
Total number of fire alarm activations	66

INJURIES FROM FIRE	
Number of injuries as a result of fire:	1
Summarise briefly the nature of the injuries below:	

Total number of Fire & Rescue Services attendance:	2
Number of automatic detectors:	910

ALL OTHER BUILDING FIRES	
Total number of major fires:	0
Total number of minor fires:	1
Total number of near miss fire incidents:	2
Total number of cooking fires:	0
Total number of external fires:	0
Number of internal that do not result in fire alarm activations:	1
Summarise briefly the nature of the fire(s)/ incidents below:	
Minor fire – Microwave oven ignited due to cooking whilst metal was in inside. Near Miss – Hot soldering iron placed onto electrical flex which melted and started smoking. Near Miss – Hot extruder part left unattended on wooden bench which started smoking.	

FALSE ALARMS	
Number of malicious alarms:	0
Number of other false activations:	19
Total number of fire alarm activations	21

INJURIES FROM FIRE	
Number of injuries as a result of fire:	0
Summarise briefly the nature of the injuries below:	

Total number of Fire & Rescue Services attendance:	7
Number of automatic detectors:	3128